

Information

Note

Non-return valves are required on System-link's outward zone flow pipe-work, only when the zone to be piped is at a higher level than the System-link. In that situation, a non-return valve must be positioned in front of the zone pump. This will prevent the creation of a gravity fed, thermo-siphoning loop, which would cause continued supply of heated water to the radiators in that zone, even when the zone's pump is no longer required and has been switched off.

